

**SAS Superstructure**

Location: 04-SF-80-13.2 / 13.9

Client Name: CalTrans

Run date 21-Nov-14

Time 11:20 AM

Daily Diary Report by Bid Item

Contract No.: 04-0120F4

Diary #: 132 Const Calendar Day: 324 Date: 29-Jul-2010 Thursday

Inspector Name: Wilcox, Jason Title: Transportation Engineer

Inspection Type: Intermittent

Shift Hours: 06:30 am 05:30 pm Break: 00:30 Over Time: 02:30

Federal ID:

Location:

Reviewer: Jefferson, Paul

Approved Date: 11-Nov-13 Status: Approved

**04-0120F4
04-SF-80-13.2/13.9
Self-Anchored
Suspension Bridge****Weather****Temperature** 7 AM 40 - 50 12 PM 50 - 60 4PM 50 - 60**Precipitation****Condition** ClearWorking Day ☒ If no, explain:**Diary:**

Dispute

General Comments**FIELD WORK:**

See David Bradd's diary for details on the E-Line and the W-Line, and Sebastian Mofor's for the Bike Path.

Incident reports written for:

- 1) 6E Top Deck weld; broke off piece, and arc strike remnants
- 2) 5E corner base plate temp weld left in place; must be removed.

OFFICE WORK:

- Safety Meeting
- Diaries
- Reviewed Plans and Specs
- Reviewed and wrote diaries
- Updated Progress Spreadsheet
- Temp Tower meeting canceled

Accrued 2.5 hours of overtime covering the Contractor's hours.

